


AISCAN TDHT

2025/01
Revisión 1 / Revision 1 / Révision 1

Tapa Derivación "T"

"T" junction cover / Couvercle dérivation "T"



Conforme UNE-EN/IEC 61537

In accordance with UNE-EN/IEC 61537 / Conformément à la norme UNE-EN/IEC 61537




G.S.	△ (kg/m)	G.C.	△ (kg/m)	A.R. C8	△ (kg/m)	A (mm)	📦 (uni.)
TDHTS100	0,55	TDHTG100	0,60	TDHTA100	0,55	100	1
TDHTS150	0,79	TDHTG150	0,87	TDHTA150	0,79	150	1
TDHTS200	1,31	TDHTG200	1,44	TDHTA200	1,31	200	1
TDHTS300	2,12	TDHTG300	2,33	TDHTA300	2,12	300	1
TDHTS400	2,56	TDHTG400	2,81	TDHTA400	2,56	400	1
TDHTS500	4,19	TDHTG500	4,61	TDHTA500	4,19	500	1
TDHTS600	5,41	TDHTG600	5,95	TDHTA600	5,41	600	1

TAPA / COVER / COUVERCLE

△ Peso / Weight / Poids

📦 Embalaje / Packing / Emballage





AISCAN TDHT

2025/01

Revisión 1 / Revision 1 / Révision 1

Material

Material / Matériau

- TDHTS: METÁLICO (acero galvanizado DX51+Z) / TDHTS: METALLIC (galvanised steel DX51+Z) / TDHTS: MÉTALLIQUE (acier galvanisé DX51+Z).
- TDHTG: METÁLICO (acero laminado en frío DC01) / TDHTG: METALLIC (cold rolled steel DC01) / TDHTG: MÉTALLIQUE (acier laminé à froid DC01).
- TDHTA: ZINC - ALUMINIO - MAGNESIO / TDHTA: ZINC - ALUMINIUM - MAGNESIUM / TDHTA: ZINC - ALUMINIUM - MAGNÉSIUM

Recubrimiento

Coating / Revêtement

- TDHTS: GALVANIZADO SENDZIMIR (G.S.) según UNE-EN 10346 / TDHTS: SENDZIMIR GALVANIZED (SG) according to UNE-EN 10346 / TDHTS: GALVANISÉ SENDZIMIR (G.S.) selon IEC/CEI-EN 10346.
- TDHTG: GALVANIZADO CALIENTE (G.C.) según UNE-EN ISO 1461 / TDHTG: HOT-DIP GALVANIZED (HDG) according to UNE-EN ISO 1461 / TDHTG: GALVANISÉ À CHAUD (G.C.) selon IEC/CEI-EN ISO 1461.
- TDHTA: GALVANIZADO SENDZIMIR "MAGNELIS" MZ / TDHTA: SENDZIMIR GALVANIZED "MAGNELIS" ZM / TDHTA: GALVANISÉ SENDZIMIR "MAGNELIS" MZ

Tornillería necesaria

Fasteners required: / Visserie nécessaire

- G.S.: mínimo / minimum / minimum: 6x CTCZ612
- G.C.: mínimo / minimum / minimum: 6x CTCG612
- A.R.: mínimo / minimum / minimum: 6x CTCG612/Zn-Ni

Características de instalación

Installation features / Caractéristiques d'installation

- La instalación de este producto se realizará según instrucciones del R.E.B.T.
- The installation of this product shall be carried out according to the instructions of the R.E.B.T.
- L'installation de ce produit sera réalisée selon les instructions du R.E.B.T.

- Aiscan, S.L. recomienda el uso exclusivo de este tipo de material por parte de profesionales.
- Aiscan, S.L. recommends the exclusive use of this type of material by professionals.
- Aiscan, S.L. recommande l'usage exclusif de ce type de matériel par des professionnels.

Copia no controlada. Esta información puede ser modificada por Aiscan sin previo aviso / Uncontrolled copy. This information may be modified by Aiscan without prior notice / Copie non contrôlée. Cette information peut être modifiée par Aiscan sans préavis.