



SALICRU, S.A.
Avenida de la Serra, 100
08460 SANTA MARIA DE PALAUTORDERA (Barcelona)
SPAIN
+34 938482400

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Uninterruptible Power System (UPS)	
	SLC CUBE4 R 7.5 ÷ 20KVA
Model:	
No:	
Date:	



SLC-7.5/10-CUBE4 R



SLC-15/20-CUBE4 R

The object of the declaration described above is in conformity with the relevant legislation of United Kingdom:

S.I. 2016 No. 1101 Electrical Equipment (Safety) Regulations 2016.

S.I. 2016 No. 1091 Electromagnetic Compatibility Regulations 2016.

S.I. 2012 No. 3032 The restriction of use of certain hazardous substances in electrical and electronic equipment Regulations 2012.

In accordance with the specifications of BSI standards:

- **BS EN IEC 62040-1:2019+A11:2021** Uninterruptible power systems (UPS) - Part 1: Safety requirements.
- **BS EN IEC 62040-2:2018** Uninterruptible Power systems (UPS). Part 2: EMC requirements.
- **BS EN IEC 61000-3-11:2019** Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems. Equipment with rated current $\leq 75A$ and subject to conditional connection.
- **BS EN IEC 61000-3-12:2011** Electromagnetic compatibility (EMC). Limits for harmonic currents produced by equipment connected to public low-voltage systems with input $> 16A$ and $\leq 75A$ per phase.

In case of any modification made by the customer to the product, the manufacturer is out of responsibility.

Santa Maria Palautordera, July, 12, 2023.

EDUARD SALICRU FITÓ
CHIEF EXECUTIVE OFFICER