

File Number **21/36403425**



## TEST REPORT

### Electromagnetic Compatibility

#### Petitioner's Reference: SALICRU

Customer Address: Avda de la Serra, 100  
08460 Palautordera – Barcelona  
Spain

#### Equipment: CUBE4 series UPS

Brand:	SALICRU	Model:	SLC-80-CUBE4
S/N:	0000448743	Internal Id:	10950/1
Internal Id:	10950/1		

#### Result: complies

It has been tested and complies the standard specifications Applicable / s.  
See specifications applied on page 13.

#### Applicable Standards

The tests / inspections marked with \* are not covered by the accreditation of ENAC

**Emission/Immunity standard/s:** \*UNE-EN 62040-2:2018 Uninterruptible power systems (UPS) - Part 2: Electromagnetic compatibility (EMC) requirements.

**CISPR 11:2015/A1:2016**  
**IEC 61000-3-11:2017**  
**IEC 61000-3-12:2011**  
**\*IEC 61000-2-2:2002**  
**IEC 61000-4-2:2008**  
**IEC 61000-4-3:2006/ISH1:2008**  
**IEC 61000-4-4:2012**  
**IEC 61000-4-5:2014/Amd1:2017**  
**IEC 61000-4-6 2013/Corr1:2015**  
**IEC 61000-4-8:2009**  
**\*IEC 61000-4-13:2002/Ams:2015**

**Date of issue:** Bellaterra, October 7, 2021

Fernando Rivas Fernández  
Technical Manager  
Electrical and Electronics  
LGAI Technological Center S.A.

The results refer only and exclusively to the sample, product or material delivered for testing in "Received Material" section above.  
The equipment has been tested under conditions stipulated by standard(s) quoted in this document.  
The document will not be reproduced otherwise than in full.  
This is the first page of the document, which consists of 46 pages.

**INDEX**

<b>1. EQUIPMENT RECEIVED AND TESTED .....</b>	<b>3</b>
1.1. TEST CONFIGURATION.....	3
1.2. AUXILIARY AND CONTROL EQUIPMENT .....	4
1.3. INPUT/OUTPUT WIRES.....	4
<b>2. APPLICABLE STANDARDS .....</b>	<b>5</b>
2.1. EMISSIONS TEST APPLICABLE STANDARDS .....	5
2.1.1. Acceptance criteria for the emissions test .....	5
2.2. IMMUNITY TESTS APPLICABLE STANDARDS.....	7
2.2.1. Acceptance criteria for the immunity test .....	8
2.3. MEASURING UNCERTAINTIES .....	9
2.4. USED EQUIPMENT.....	10
2.5. ENVIRONMENTAL CONDITIONS .....	12
<b>3. RESULT .....</b>	<b>13</b>
<b>4. ANNEXES .....</b>	<b>14</b>
4.1. IDENTIFICATION PICTURES.....	14
4.2. RESULTS DETAILS.....	18

## 1. EQUIPMENT RECEIVED AND TESTED

Equipment: CUBE4 series UPS			
<b>Brand:</b>	SALICRU	<b>Model:</b>	SLC-80-CUBE4
<b>S/N:</b>	0000448743	<b>Power Supply:</b>	400 V 3ph 50/60 Hz
<b>SW:</b>	--	<b>HW:</b>	--

**DUT information:**

*(Information declared by the manufacturer, Applus + is not responsible).*

UPS classified as C3 according product standard, intended for second environment and industrial areas. Internal batteries supplied.

SLC-50-CUBE4, SLC-60-CUBE4 and SLC-80-CUBE4 have same structure and format.



<b>Test product reception:</b>	May 10, 2021
<b>Test initial date:</b>	May 10, 2021
<b>Test final date:</b>	June 18, 2021

### 1.1. Test configuration

<b>Power Supply:</b>	400 V 3ph 50 Hz.
<b>Set-up:</b>	Floor standing.
<b>Test exercise:</b>	Equipment continuously working. DC Output voltage and current measured and operation mode checked on display.
<b>Equipment size:</b>	560 mm x 1655 mm x 920 mm Note: According product standard, C3 equipment classified for second environment.

The tests / inspections marked with \* are not covered by the accreditation of ENAC

### **1.2. Auxiliary and control equipment**

The equipment under test does not have any auxiliary or control equipment.

---

### **1.3. Input/output wires**

- Battery cable < 3m length
  - AC Output cable
  - AC Input cable
-

## 2. APPLICABLE STANDARDS

### 2.1. EMISSIONS TEST APPLICABLE STANDARDS

Test Plan Summary:	
<b>Basic standard:</b> CISPR 11:2015/A1:2016	
<input checked="" type="checkbox"/> Radio-frequency radiated emissions (30 MHz-1000 MHz)	Class: C3
<b>Basic standard:</b> CISPR 11:2015/A1:2016	
<input checked="" type="checkbox"/> Continuous conducted emissions (0.15-30 MHz)	Class: C3
Note: AC input and Output port.	
<b>Basic standard:</b> IEC 61000-3-11:2017	
<input checked="" type="checkbox"/> Voltage fluctuations emissions	Pst 1<, Plt 0,65<, Tmax 500 mS @3 %, dc 3,3 %, dmax
<b>Basic standard:</b> IEC 61000-3-12:2011 , *IEC 61000-2-2:2002	
<input checked="" type="checkbox"/> Harmonic current emissions	Class: A

#### 2.1.1. Acceptance criteria for the emissions test

According to standard      **\*UNE-EN 62040-2:2018**  
 Limit                              Table 2 for conducted emissions.  
    Table 3 for radiated emissions

**Table 2 – Limits of mains terminal and network port disturbance voltage for category C3 UPS in the frequency range 0,15 MHz to 30 MHz**

UPS rated output current	Frequency range MHz	Limits dB (μV)			
		Mains terminal		Network port	
		Quasi-peak	Average	Quasi-peak	Average
> 16 to 100	0,15 to 0,50 <sup>b</sup>	100	90	110 to 100 <sup>a</sup>	94 to 84 <sup>a</sup>
	0,50 to 5,0 <sup>b</sup>	86	76	100	84
	5,0 to 30,0	90 to 73 <sup>a</sup>	80 to 60 <sup>a</sup>		
> 100	0,15 to 0,50 <sup>b</sup>	130	120	110 to 100 <sup>a</sup>	94 to 84 <sup>a</sup>
	0,50 to 5,0 <sup>b</sup>	125	115	100	84
	5,0 to 30,0	115	105		

<sup>a</sup> The limits decrease linearly with the logarithm of the frequency.  
<sup>b</sup> The lower limit shall apply at the transition frequency.

**Table 3 – Limits of radiated emission in the frequency range 30 MHz to 1 000 MHz**

Frequency range MHz	Quasi-peak limits dB ( $\mu\text{V/m}$ )		
	Category C1 UPS	Category C2 UPS	Category C3 UPS
30 to 230 <sup>a</sup>	30	40	50
230 to 1 000	37	47	60

<sup>a</sup> The lower limit shall apply at the transition frequency.

According to standard **IEC 61000-3-12:2011**

Limit **Table 3**

**Table 3 – Current emission limits for balanced three-phase equipment**

Minimum $R_{sce}$	Admissible individual harmonic current $I_h/I_{ref}$ <sup>a</sup> %				Admissible harmonic parameters %	
	$I_5$	$I_7$	$I_{11}$	$I_{13}$	$THC/I_{ref}$	$PWHC/I_{ref}$
33	10,7	7,2	3,1	2	13	22
66	14	9	5	3	16	25
120	19	12	7	4	22	28
250	31	20	12	7	37	38
$\geq 350$	40	25	15	10	48	46

The relative values of even harmonics up to order 12 shall not exceed  $16/h$  %. Even harmonics above order 12 are taken into account in  $THC$  and  $PWHC$  in the same way as odd order harmonics.

Linear interpolation between successive  $R_{sce}$  values is permitted.

<sup>a</sup>  $I_{ref}$  = reference current;  $I_h$  = harmonic current component.

---

According to standard **IEC 61000-3-11:2017**

Limit **Paragraph 5**

**Pst 1<, Plt 0,65<, Tmax 500mS @3%, dc 3,3%, dmax**

---

## 2.2. IMMUNITY TESTS APPLICABLE STANDARDS

Test Plan Summary:	
<b>Basic standard:</b> IEC-61000-4-2:2008	
<input checked="" type="checkbox"/> Electrostatic discharge immunity	Level AC: ±8 kV    Level DC ±4 kV
<b>Basic standard:</b> IEC 61000-4-3:2006/ISH1:2008	
<input checked="" type="checkbox"/> Electromagnetic field immunity.	Frequency range: 80 MHz-1000 MHz Severity: 10 V/m Modulation: 80% AM 1 kHz
<b>Basic standard:</b> IEC 61000-4-4:2012	
<input checked="" type="checkbox"/> Fast transients in burst immunity.	
<input type="checkbox"/> Severity level in signal and control ports	Severity: ±2 kV 5 kHz
<input checked="" type="checkbox"/> Severity level in ground terminal	Severity: ±2 kV 5 kHz
<input checked="" type="checkbox"/> Severity level in I/O port of AC power Supply	Severity: ±2 kV 5 kHz
<b>Basic standard:</b> IEC 61000-4-5:2014/Amd1:2017	
<input checked="" type="checkbox"/> Surge transients immunity.	
<input type="checkbox"/> Communications port if cable length >30m.	Common mode severity: ± 1 kV Differential mode severity: --
<input checked="" type="checkbox"/> AC supply ports.	Common mode severity: ±2 kV Differential mode severity: ±1 kV
<b>Basic standard:</b> IEC 61000-4-6:2013/Corr1:2015	
<input checked="" type="checkbox"/> Current injections immunity.	
<input type="checkbox"/> Signal and control ports.	Severity: 10 V RMS
<input checked="" type="checkbox"/> AC Supply and access by ground terminal.	Severity: 10 V RMS
<b>Basic standard:</b> IEC 61000-4-8:2009	
<input checked="" type="checkbox"/> Magnetic field immunity	50 Hz 30 A/m
<b>Basic standard:</b> *IEC 61000-4-13:2002/Ams:2015, *IEC 61000-2-2:2002	
<input checked="" type="checkbox"/> Harmonics and inter-harmonics including mains signalling at A.C. power port, low frequency immunity tests	Class: 10 V between 140-360 Hz
According Table 1 of IEC 61000-2-2 Compatibility levels (applying level 3 of IEC 61000-4-3, all levels and frequencies are covered).	

The tests / inspections marked with \* are not covered by the accreditation of ENAC

### 2.2.1. Acceptance criteria for the immunity test

According to standard                    **\*UNE-EN 62040-2:2018**  
Section                            6.2, table 4

**Table 4 – Performance criteria for immunity tests**

	<b>Criterion A</b>	<b>Criterion B</b>
External and internal indications and metering	Change only during test	Change only during test
Control signals to external devices	No change	Change only temporarily in consistency with the actual UPS mode of operation
Mode of operation <sup>a</sup>	No change	Change only temporarily

<sup>a</sup> At all times, the UPS shall remain within the performance classification as declared by the UPS manufacturer (see IEC 62040-3:2011).

The tests shall be made with the UPS in the following conditions:

- a) rated input voltage;
- b) normal mode(s) of operation;
- c) linear load at rated active output power or at light load according to IEC 62040-3:2011.

The UPS shall be specified with the proper level in case of different levels of performance criteria.

### 2.3. Measuring uncertainties

Radio-frequency radiated emissions:	± 4.3 dB
Continuous conducted emissions:	± 2.1 dB
Electrostatic discharges immunity:	± 1.65 dB
Electromagnetic field immunity:	± 2.45 dB
Fast transients in burst immunity:	± 1.3 dB
Surge transients immunity:	± 1.3 dB
Current injections immunity:	± 1.7 dB
Low frequency magnetic field immunity	± 1.,01 dB
Inter-harmonics immunity	± 0.8 dB

---

Expanded uncertainty measurement is obtained multiplying the typical uncertainty measurement with a coverage factor  $k=2$ , which corresponds to a confidence level of 95% for a normal distribution.

## 2.4. USED EQUIPMENT

RADIO-FREQUENCY RADIATED EMISSIONS			
INSTRUMENT	BRAND	MODEL	NUMBER
EMI TEST RECEIVER	ROHDE & SCHWARZ	ESU 40	1041155
TRILOG ANTENNA	SCHWARZBECK	VULB 9165	104375
ATTENUATOR 3dB	HUBER+SUHNER	6803.17.B	1042016
RF CABLE (Ferrites Cable)	ER+SUHNER	CLR67 NANA 10000 P01 FR	1042114
RF PREAMPLIFIER	BONN ELEKTRONIK	BLNA 0110-01N	1041351
DC BLOCK	WEINSCHEL	WA6043	1042486
RF CABLE (Short Cable)	REDISLOGAR	SF104	1042328
RF CABLE (Wall panel)	-	-	1041305
RF CABLE (Control Room)	HUBER+SUHNER	SF103/11N/16N/4000MM	1041911
SEMIANECHOIC CHAMBER SAC0	TDK	TC0	104380
TEST SOFTWARE	ROHDE & SCHWARZ	EMC32 v.10.50.00	104624
MAST-TABLE CONTROLLER	MATURO	NCD/052/8931211	1041952
ANTENNA TOWER	MATURO	-	--
TURNABLE	MATURO	--	--

CONTINUOUS CONDUCTED EMISSIONS			
INSTRUMENT	BRAND	MODEL	NUMBER
EMI RECEIVER	RHODE & SCHWARZ	ESCS30	104952
LISN	RHODE & SCHWARZ	NNLK 8121	104025
TRANSIENT LIMITER	SCHWARZBECK	VTSD 9561-F	1042102
SEMIANECHOIC CHAMBER SAC0	TDK	TC0	104380
TEST SOFTWARE	ROHDE & SCHWARZ	EMC32 v.10.50.00	104624

ELECTROSTATIC DISCHARGE IMMUNITY			
INSTRUMENT	BRAND	MODEL	NUMBER
ESD GENERATOR	HAEFLEY	ONIX	1041978

ELECTROMAGNETIC FIELD IMMUNITY			
INSTRUMENT	BRAND	MODEL	NUMBER
SEMIANECHOIC CHAMBER	TDK	TC0 TEST CHAMBER	104380
POWER AMPLIFIER	AR	1000W1000M12	104151
SIGNAL GENERATOR	ROHDE & SCHWARZ	SMB-100A	1041117
POWER METER	ROHDE & SCHWARZ	NRP2	1041240
POWER METER SENSOR	ROHDE & SCHWARZ	NRP-Z91	1041116
POWER METER SENSOR	ROHDE & SCHWARZ	NRP-Z91	1041115
OPEN SWITCH AND CONTROL UNIT	ROHDE & SCHWARZ	OSP220	--
DIRECTIONAL COUPLER	ROHDE & SCHWARZ	DDC25-BC60	1042393
LOG PERIODIC ANTENNA	EMC AUTOMATION	LPD80	104457
TEST SOTFTWARE	ROHDE & SCHWARZ	EMC32 v.10.50.00	104624
COMPUTER SYSTEM (CONTROLER)	HP	HP-ProBook 640 G2	6921
TURN TABLE	HD	DT 470	104379
TURN TABLE CONTROLLER	MATURO	NCD/052/8931211	--
RF CABLE	SPANTECH	TRU-14221-39 mfd 1911	1042324
E-FIELD PROBE	NARDA	EP601	1041797

FAST TRANSIENTS IN BURST IMMUNITY			
INSTRUMENT	BRAND	MODEL	NUMBER
FAST TRANSIENT/BURST GENERATOR	SCHAFFNER	NSG 2025	104019
COUPLING CLAMP	SCHAFFNER	CDN 126	104043

SURGE TRANSIENTS IMMUNITY (1,2/50)			
INSTRUMENT	BRAND	MODEL	NUMBER
IMPULSE SURGE PLATFORM	HAEFELY TECHNOLOGY	PSurge 8000 + PIM 100	104888
CDN	HAEFELY TECHNOLOGY	PCD 130	104889

SURGE TRANSIENTS IMMUNITY (1,2/50)			
INSTRUMENT	BRAND	MODEL	NUMBER
IMPULSE SURGE PLATFORM	HAEFELY TECHNOLOGY	PSURGE800+PIM100	104888
CDN	HAEFELY TECHNOLOGY	PDC 130	104889
CDN	HAEFELY TECHNOLOGY	PCD 126	104908

The tests / inspections marked with \* are not covered by the accreditation of ENAC

<b>CURRENT INJECTIONS IMMUNITY</b>			
<b>INSTRUMENT</b>	<b>BRAND</b>	<b>MODEL</b>	<b>NUMBER</b>
SIGNAL GENERATOR	R&S	SMB100A	1041781
ATTENUATOR	BIRD	150-A-MFN-06	1041645
AMPLIFIER	EMC AUTOMATION	EA4937	104124
CLAMP	LÜTHI	EM101	1041244
POWER METER	R&S	NRP	1041114
TEST SOFTWARE	ROHDE & SCHWARZ	EMC32 v.10.50.00	104624

<b>VOLTAGE VARIATIONS IMMUNITY, HARMONIC EMISSIONS, FLICKER EMISSIONS</b>			
<b>INSTRUMENT</b>	<b>BRAND</b>	<b>MODEL</b>	<b>NUMBER</b>
AIP (Line Impedance Simulation Net)	SPITZENBERGER & SPIES	AIP 75/3/P/JK	1041157
FUENTE DE ALIMENTACIÓN	SPITZENBERGER & SPIES	PAS 45000	--
TEST SOFTWARE	SPS EMC	4.1.1	--

<b>MAGNETIC FIELD IMMUNITY</b>			
<b>INSTRUMENT</b>	<b>BRAND</b>	<b>MODEL</b>	<b>NUMBER</b>
MAGNETIC FIELD PROBE	COMBINOVA	MFM 10	104023
AC Power supply	SCHAFFNER	PACIFIC	101933
INDUCTION COIL	SCHAFFNER	888-0239	05-ER-355

<b>AUXILIARY EQUIPMENT</b>			
<b>INSTRUMENT</b>	<b>BRAND</b>	<b>MODEL</b>	<b>NUMBER</b>
THERMOHIGROMETER	PCE	THB 40	1042022
MULTIMETER*	FLUKE	115	1041346

## 2.5. Environmental conditions

See results sheets.

The tests / inspections marked with \* are not covered by the accreditation of ENAC

### 3. RESULT

PRODUCT: CUBE4 series UPS			
<b>Brand:</b>	SALICRU	<b>Model:</b>	SLC-80-CUBE4
<b>S/N:</b>	0000448743	<b>Power Supply:</b>	400 V 3ph 50 Hz
EMISSION TESTING		RESULTS	NOTES
Radio-frequency radiated emissions.		Pass	Note: 4
Continuous conducted emissions.		Pass	Note: 4
Harmonic current emissions		Pass	Note: 4
Flicker emissions		Pass	Note: 4
<p>The criteria to give conformity in those cases where it is not implicit in the standard or specification will be, for EMC emissions tests, a non-simple binary decision rule will be followed with a safety zone equal to the value of the uncertainty (<math>w = U</math>).</p> <p>In this case, the upper limit of the value of the probability of false acceptance, according to ILAC G8, is 2.5% and the criteria notes are:</p> <p><b>1:</b> The measured results are above the upper limit, even considering the uncertainty interval.  <b>2:</b> The measured results are above the specified limits, but within the uncertainty interval. It is therefore not possible to state compliance based on the 95% level of confidence. However, the results indicate that non-compliance is more probable than compliance  <b>3:</b> The measured results are below the specified limits, but within the uncertainty interval. It is therefore not possible to state compliance based on the 95% level of confidence. However, the results indicate that compliance is more probable than non-compliance  <b>4:</b> The measured results are within the limits, including the uncertainty interval.</p>			
IMMUNITY TESTING		RESULTS	REQUIRED CRITERIA
Electrostatic discharges immunity.		Pass (A)	Criteria: B
Electromagnetic field immunity.		Pass (A)	Criteria: A
Fast transients in burst immunity.		Pass (A)	Criteria: B
Surge transients immunity.		Pass (A)	Criteria: B
Current injections immunity.		Pass (A)	Criteria: A
Voltage variations immunity.		Pass (A)	Criteria: A
Inter harmonics immunity		Pass (A)	Criteria: A
Magnetic field immunity		Pass (A)	Criteria: A
<p>The criteria to give conformity in those cases where it is not implicit in the standard or specification will be, for EMC immunity tests, a simple binary decision rule will be followed where the upper limit of the value of the probability of false acceptance or false rejection, according to ILAC G8, is 50%.</p>			

#### Service Quality Assurance

**Applus+**, guarantees that this work has been made in accordance with our Quality and Sustainability System, fulfilling the contractual conditions and legal norms.

Within our improvement program we would be grateful if you would send us any commentary that you consider opportune, to the person in charge who signs this document, or to the Quality Manager of Applus+, in the following e-mail address: [satisfaccion.cliente@applus.com](mailto:satisfaccion.cliente@applus.com)

**The tests / inspections marked with \* are not covered by the accreditation of ENAC**

**4. ANNEXES**

**4.1. Identification pictures**


**General view**




Front view



Rear view



Front display view



Lateral view



Applus identifier label (definitive label model)





Factory Identifier label (tested equipment)



**ID: 10950/1**  
 Cliente: SALICRU  
 SLC CUBE4 3/3 80kVA+291820C03344  
 Fecha de entrada  
 2021-05-10

Applus identifier label


**Test configuration**




**Radio-frequency radiated emissions**




**Continuous conducted emissions**




**Electrostatic discharges immunity**




**Electromagnetic field immunity 80 MHz to 1 GHz**



Fast transients in burst immunity



Surge transients immunity



Current injections immunity



Voltage variations immunity, flicker emissions and harmonic current emissions

**The tests / inspections marked with \* are not covered by the accreditation of ENAC**




Magnetic field immunity

#### 4.2. Results Details

RADIO-FREQUENCY RADIATED EMISSIONS														
<b>Technician:</b> J.J.Permos			<b>Frequency range:</b> 30 MHz – 1 GHz											
<b>Test date:</b> 2021-05-10			<b>Test Area:</b> Semi-Anechoic chamber, SAC-0											
<b>Basic standard: CISPR 11:2015</b>														
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>22.1</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>61.3</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1006.6</td> <td>hPa</td> </tr> </table>						<b>Temperature:</b>	22.1	°C	<b>Humidity:</b>	61.3	%	<b>Atm. Pressure:</b>	1006.6	hPa
<b>Temperature:</b>	22.1	°C												
<b>Humidity:</b>	61.3	%												
<b>Atm. Pressure:</b>	1006.6	hPa												
EUT:	Class	Test Area	Distance	PreScan	Evaluation									
Floor standing	C3	SAC-0	10 m	4 faces	Individual									
<b>RESULTS:</b> Pass														
Identification		Emissions		Main emission source and type										
DUT: Device under test AUX: Auxiliary Devices SYS: DUT + AUX BB: Broad-band NB: Narrow-band QP: Quasi-peak		QP < Limit - I  I=Uncertainty		DUT, BB										
Comments														
<p><i>Emission Level = Measured Level + Correction Factor</i></p>														

**RADIO-FREQUENCY RADIATED EMISSIONS II**

**PRESCAN MODE 1 30 MHz – 1 GHz**



— Preview Result 1-PK+    — 10 m Category C3 30-1000MHz    ◆ Final\_Result QPK

**FINAL MEASUREMENTS**

Frequency (MHz)	QuasiPeak (dBµV/m)	Limit (dBµV/m)	Margin (dB)	Height (cm)	Pol	Azimuth (deg)	Corr. (dB/m)	Comment
46.110	38.96	50.00	11.04	200.0	V	324.0	-26.9	BB
111.330	27.35	50.00	22.65	155.0	V	178.0	-27.6	BB
120.270	23.88	50.00	26.12	263.0	H	0.0	-26.5	BB
150.510	31.39	50.00	18.61	400.0	H	275.0	-20.4	BB
166.920	24.79	50.00	25.21	100.0	V	196.0	-19.5	BB
176.160	30.51	50.00	19.49	400.0	V	193.0	-22.1	BB


**Comments:**

<b>CONTINUOUS CONDUCTED EMISSIONS</b>	
<b>Technician:</b> Alfredo Plans	<b>Test Area:</b> Semi-Anechoic chamber, SAC-0
<b>Test date:</b> 2021-05-10	
<b>Basic standard:</b> CISPR 11:2015	
<b>Temperature:</b>	22.0 °C
<b>Humidity:</b>	56.9 %
<b>Atm. Pressure:</b>	1005.3 hPa
<b>CONTINUOUS CONDUCTED EMISSIONS</b>	
<b>Supply</b>	
<b>Mains Supply</b>	
T. in power Supply: (dBµV)	Pass Vpeak < lim AVG
<b>Source and type of the most important emissions</b>	
<b>Source:</b> Device under test	<b>Type:</b> Broad Band
<b>RESULTS:</b> Pass	
<b>Comments:</b>	

**CONTINUOUS CONDUCTED EMISSIONS II**

**LINE NEUTRAL**

**AC INPUT PORT PRESCAN**




**FINAL MEASUREMENTS**

Frequency (MHz)	QuasiPeak (dBµV)	Limit - QPK (dBµV)	Margin - QPK (dB)	Average (dBµV)	Limit - AVG (dBµV)	Margin - AVG (dB)	Line	Corr. (dB)
0.158	68.8	100.0	31.2	62.4	90.0	27.6	N	10.2
0.218	64.5	100.0	35.5	58.2	90.0	31.8	N	10.2
0.238	65.0	100.0	35.0	59.9	90.0	30.1	N	10.2
1.378	55.2	86.0	30.8	49.6	76.0	26.4	N	10.3
7.410	57.0	86.0	29.0	50.3	75.1	24.8	N	10.6
12.610	49.2	80.8	31.6	41.5	69.0	27.5	N	10.7
18.594	44.1	77.2	33.1	37.0	64.8	27.8	N	10.9
21.978	44.5	75.7	31.2	34.9	63.1	28.2	N	11.0

**CONTINUOUS CONDUCTED EMISSIONS II**

**LINE L1**

**AC INPUT PORT PRESCAN**



— LINE L1 PK+\_MAXH      — LINE L1 AVG\_MAXH      — C3\_QP  
— C3\_AV      ▼ Average-AVG (Single)      ▲ QuasiPeak-QPK (Single)


**FINAL MEASUREMENTS**

Frequency (MHz)	QuasiPeak (dBµV)	Limit - QPK (dBµV)	Margin - QPK (dB)	Average (dBµV)	Limit - AVG (dBµV)	Margin - AVG (dB)	Line	Corr. (dB)
0.158	72.2	100.0	27.8	66.6	90.0	23.4	L1	10.2
0.170	64.2	100.0	35.9	44.1	90.0	45.9	L1	10.2
1.602	48.3	86.0	37.7	41.8	76.0	34.2	L1	10.4
2.258	48.4	86.0	37.6	39.4	76.0	36.6	L1	10.4
7.378	45.1	86.0	40.9	38.8	75.2	36.3	L1	10.6
8.890	44.5	84.1	39.7	36.3	72.9	36.6	L1	10.6
10.470	44.5	82.6	38.0	38.5	71.0	32.6	L1	10.7
14.654	38.5	79.4	40.9	30.3	67.3	37.0	L1	11.0

**CONTINUOUS CONDUCTED EMISSIONS III**

**LINE L2**

**AC INPUT PORT PRESCAN**




**FINAL MEASUREMENTS**

Frequency (MHz)	QuasiPeak (dBµV)	Limit - QPK (dBµV)	Margin - QPK (dB)	Average (dBµV)	Limit - AVG (dBµV)	Margin - AVG (dB)	Line	Corr. (dB)
0.162	70.8	100.0	29.2	64.0	90.0	26.0	L2	10.2
0.170	64.3	100.0	35.7	42.9	90.0	47.1	L2	10.2
0.182	65.3	100.0	34.7	58.3	90.0	31.7	L2	10.2
1.518	50.4	86.0	35.6	44.5	76.0	31.5	L2	10.3
2.238	46.7	86.0	39.3	37.5	76.0	38.5	L2	10.3
12.650	42.4	80.7	38.3	35.1	68.9	33.8	L2	10.8
14.498	41.3	79.5	38.1	33.9	67.4	33.5	L2	10.9
18.946	42.1	77.0	34.9	33.9	64.6	30.7	L2	10.9

**CONTINUOUS CONDUCTED EMISSIONS IV**

**LINE L3**

**AC INPUT PORT PRESCAN**



— LINE L3 AVG\_CLRWR      — LINE L3 PK+\_CLRWR      — C3\_QP  
— C3\_AV      ▼ Average-AVG (Single)      ▲ QuasiPeak-QPK (Single)

**FINAL MEASUREMENTS**

Frequency (MHz)	QuasiPeak (dBµV)	Limit - QPK (dBµV)	Margin - QPK (dB)	Average (dBµV)	Limit - AVG (dBµV)	Margin - AVG (dB)	Line	Corr. (dB)
0.158	68.4	100.0	31.6	61.8	90.0	28.2	L3	10.1
0.218	62.7	100.0	37.3	57.1	90.0	32.9	L3	10.1
0.322	59.9	100.0	40.1	52.7	90.0	37.3	L3	10.1
1.598	47.7	86.0	38.3	41.5	76.0	34.5	L3	10.2
2.242	45.9	86.0	40.1	36.8	76.0	39.2	L3	10.2
7.,370	38.9	86.0	47.1	32.3	75.2	42.9	L3	10.4
15.926	35.8	78.6	42.8	27.2	66.4	39.2	L3	10.7
20.986	34.8	76.1	41.3	26.6	63.5	36.9	L3	10.9

VOLTAGE FLUCTUATIONS EMISSION

**Technician:** Andreu Tey **Test Area:** Ground plane  
**Test date:** 2021-06-04

**Basic standard: IEC 61000-3-11:2017**

<b>Temperature:</b>	23.5	°C
<b>Humidity:</b>	58.9	%
<b>Atm. Pressure:</b>	1002.1	hPa

**RESULTS:** Pass

**Line - R**

Test conditons: EN 61000-3-11:2019 / 230 V / 50 Hz / Phase L1  
 EN 61000-4-15:2011 / d(t) = 1.8 % / Obs 1 x 10 min / Ztest (0.025+j0.250) Ohm  
 Ra+jXa (0.0150+j0.1500) Ohm / Rn+jXn (0.0100+j0.1000) Ohm

FLICKER (EN 61000-3-11 recalculated to Zref): Test PASS!

Time	Pmax	Pst	Sliding Plt	Tmax [s]	dmax [%]	dc [%]	PASS	FAIL
08:41:05	1.378	0.3417	0.3417	0.000	-0.957	-0.638	X	
Limits:		1.000	0.650	0.500	4.000	3.300		
Plt: 0.341693								
Evaluated: PST, dc, dmax, Tmax								

FLICKER: Source test PASS!

Time	Pmax	Pst	Sliding Plt	Tmax [s]	dmax [%]	dc [%]	PASS	FAIL
08:41:05	0.001	0.0270	- . - . - . - .	0.000	+0.000	- . - . - . - .	X	
Plt: 0.027000								
Evaluated: PST <= 0.4 dmax < 20 % dmax1								

Tested with SPSEMC4.4.3 / PAS1000 by Spitzenberger & Spies GmbH & Co. KG, Schmidstr. 32-34 94234 Viechtach, Germany, 04.06.2021

**Comments:**

**VOLTAGE FLUCTUATIONS EMISSION II**

**Line – S**

Test conditons: EN 61000-3-11:2019 / 230 V / 50 Hz / Phase L2  
 EN 61000-4-15:2011 / d(t) = 1.8 % / Obs 1 x 10 min / Ztest (0.025+j0.250) Ohm  
 Ra+jXa (0.0150+j0.1500) Ohm / Rn+jXn (0.0100+j0.1000) Ohm

FLICKER (EN 61000-3-11 recalculated to Zref): Test PASS!

Time	Pmax	Pst	Sliding Plt	Tmax [s]	dmax [%]	dc [%]	PASS	FAIL
08:53:08	4.288	0.3849	0.3849	0.000	-1.690	-0.957	X	
Limits:		1.000	0.650	0.500	4.000	3.300		
Plt: 0.384874							X	
Evaluated: PST, PLT, Sliding PLT, dc, dmax, Tmax								

FLICKER: Source test PASS!

Time	Pmax	Pst	Sliding Plt	Tmax [s]	dmax [%]	dc [%]	PASS	FAIL
08:53:08	0.015	0.0860	- . - - -	0.000	+0.000	- . - - -	X	
Plt: 0.086000								
Evaluated: PST <= 0.4 dmax < 20 % dmax1								

Tested with SPSEMC4.4.3 / PAS15000 by Spitzenberger & Spies GmbH & Co. KG, Schmidstr. 32-34 94234 Viechtach, Germany, 04.06.2021

**VOLTAGE FLUCTUATIONS EMISSION III**

**Line – T**

Test conditions: EN 61000-3-11:2019 / 230 V / 50 Hz / Phase L3  
 EN 61000-4-15:2011 / d(t) = 1.8 % / Obs 1 x 10 min / Zest (0.025+j0.250) Ohm  
 Ra+jXa (0.0150+j0.1500) Ohm / Rn+jXn (0.0100+j0.1000) Ohm

FLICKER (EN 61000-3-11 recalculated to Zref): Test PASS!

Time	Pmax	Pst	Sliding Plt	Tmax [s]	dmax [%]	dc [%]	PASS	FAIL
09:06:35	1.842	0.3586	0.3586	0.000	-1.577	+0.901	X	
Limits:		1.000	0.650	0.500	4.000	3.300		
Plt: 0.358590							X	
Evaluated: PST, PLT, Sliding PLT, dc, dmax, Tmax								

FLICKER: Source test PASS!

Time	Pmax	Pst	Sliding Plt	Tmax [s]	dmax [%]	dc [%]	PASS	FAIL
09:06:35	0.015	0.0860	- . - - -	0.000	+0.000	- . - - -	X	
Plt: 0.086000								
Evaluated: PST <= 0.4 dmax < 20 % dmax1								

Tested with SPSEMC4.4.3 / PAS1000 by Spitzenberger & Spies GmbH & Co. KG, Schmidstr. 32-34 94234 Viechtach, Germany, 04.06.2021


**HARMONIC CURRENT EMISSION**

**Technician:** Andreu Tey **Test Area:** Ground plane  
**Test date:** 2021-06-04

**Basic standard:** IEC 61000-3-12:2011

<b>Temperature:</b>	23.5	°C
<b>Humidity:</b>	58.9	%
<b>Atm. Pressure:</b>	1002.1	hPa

**RESULTS:** Pass



**Comments:**

**HARMONIC CURRENT EMISSION II**

Maximum RMS current and corresponding values in timewindow 14:

Voltage: 230.71 V rms THD=0.07 % THV=0.154 V POHV=0.074 V PWHD=0.25 %  
 Current: 53.283 Arms THD=5.99 % THC=3.165 A POHC=0.000 A PWHD=6.77 %  
 Power: 12176.4 W P1=12176.8 W 12292.9 VA THC/Iref=5.95%  
 Power factor: 0.991 C<sub>os</sub>Phi1: 0.999 PWHC/Iref=6.72%

Test conditons: EN 61000-3-12:2011, f=50 Hz, Phase=L1, Range=80.00 A  
 Time window=10/12 (200ms), Grouping (>2nd harm.)=on, I<sub>eq</sub>=53.161 A, Rated R<sub>sc</sub>=33  
 No Ztest selected, Inserted reactor impedance: --  
 harmonic currents < 1 % of I<sub>ref</sub> are disregard for calc. of THD, THC, POHC, PWHD, PWHC

HARMONIC ANALYSIS: Test PASS

Tobs = worst 2.5 min: tw 1..750; Avg: THC/Iref=6.0 % , PWHC/Iref=8.1 % (Limits: THC/Iref=13.0 % , PWHC/Iref=22.0 % ); I<sub>avg</sub>=53.161 Arms; I<sub>ref</sub> is set to I<sub>eq</sub>


Ha	Entire measurement (2.5 min = 750 time windows)						Worst 2.5 min		Worst 2.5 min avg		P A S S	F A I L
	Maximum	Window	EN61000-3-12 Balanced 3ph	Margin in MaxWin	100 to 150%	Ex- ceeded	100 to 150%	Ex- ceeded	Value	Ex- ceeded		
DC	-6.2721 A	236	-----	-----	0	0	0	0	-6.1332 A	0	--	
1	52.8161 A	14	-----	-----	0	0	0	0	52.6882 A	0	X	
2	1.1651 A	3	4.2529 A	-72.6 %	0	0	0	0	1.1091 A	0	X	
3	0.7170 A	400	-----	-----	0	0	0	0	0.6166 A	0	X	
4	0.1845 A	216	2.1264 A	-91.3 %	0	0	0	0	0.1253 A	0	X	
5	1.8770 A	140	5.6882 A	-67.0 %	0	0	0	0	1.8057 A	0	X	
6	0.4699 A	588	1.4176 A	-66.9 %	0	0	0	0	0.4241 A	0	X	
7	1.3630 A	620	3.8276 A	-64.4 %	0	0	0	0	1.3213 A	0	X	
8	0.1681 A	179	1.0632 A	-84.2 %	0	0	0	0	0.1082 A	0	X	
9	1.0085 A	500	-----	-----	0	0	0	0	0.9628 A	0	X	
10	0.2366 A	175	0.8506 A	-72.2 %	0	0	0	0	0.2040 A	0	X	
11	1.0395 A	705	1.6480 A	-36.9 %	0	0	0	0	1.0122 A	0	X	
12	0.2536 A	132	0.7088 A	-64.2 %	0	0	0	0	0.2286 A	0	X	
13	0.8502 A	54	1.0632 A	-20.0 %	0	0	0	0	0.8136 A	0	X	
14	0.2349 A	199	-----	-----	0	0	0	0	0.2110 A	0	X	
15	0.7184 A	661	-----	-----	0	0	0	0	0.6830 A	0	X	
16	0.2826 A	195	-----	-----	0	0	0	0	0.2575 A	0	X	
17	0.6133 A	175	-----	-----	0	0	0	0	0.5950 A	0	X	
18	0.2694 A	68	-----	-----	0	0	0	0	0.2552 A	0	X	
19	0.5477 A	161	-----	-----	0	0	0	0	0.5350 A	0	X	
20	0.2539 A	737	-----	-----	0	0	0	0	0.2420 A	0	X	
21	0.4842 A	69	-----	-----	0	0	0	0	0.4677 A	0	X	
22	0.2474 A	615	-----	-----	0	0	0	0	0.2399 A	0	X	
23	0.4225 A	127	-----	-----	0	0	0	0	0.4129 A	0	X	
24	0.2467 A	750	-----	-----	0	0	0	0	0.2332 A	0	X	
25	0.3756 A	495	-----	-----	0	0	0	0	0.3655 A	0	X	
26	0.2281 A	630	-----	-----	0	0	0	0	0.2206 A	0	X	
27	0.3324 A	255	-----	-----	0	0	0	0	0.3217 A	0	X	
28	0.2165 A	324	-----	-----	0	0	0	0	0.2070 A	0	X	
29	0.2937 A	670	-----	-----	0	0	0	0	0.2862 A	0	X	
30	0.2090 A	177	-----	-----	0	0	0	0	0.1999 A	0	X	
31	0.2686 A	243	-----	-----	0	0	0	0	0.2627 A	0	X	
32	0.2012 A	258	-----	-----	0	0	0	0	0.1962 A	0	X	
33	0.2285 A	249	-----	-----	0	0	0	0	0.2207 A	0	X	
34	0.1999 A	445	-----	-----	0	0	0	0	0.1920 A	0	X	
35	0.2164 A	515	-----	-----	0	0	0	0	0.2110 A	0	X	
36	0.2018 A	524	-----	-----	0	0	0	0	0.1955 A	0	X	
37	0.1910 A	70	-----	-----	0	0	0	0	0.1871 A	0	X	
38	0.1958 A	516	-----	-----	0	0	0	0	0.1897 A	0	X	
39	0.1719 A	419	-----	-----	0	0	0	0	0.1693 A	0	X	
40	0.1938 A	248	-----	-----	0	0	0	0	0.1877 A	0	X	

average value < 1.0 % of Iref

Tested with SPS EMC 44.3 / PAS1900 by Spitzenberger & Spjes GmbH & Co. KG, Schmidstr. 32-34, 94234 Viechtach, Germany, 04.06.2021

HARMONIC CURRENT EMISSION III

Line- S



**HARMONIC CURRENT EMISSION IV**

Maximum RMS current and corresponding values in timewindow 115:

Voltage: 230.44 Vrms THD=0.03 % THV=0.060 V POHV=0.030 V PWH=0.07 %  
Current: 53.793 Arms THD=2.79 % THC=1.496 A POHC=0.000 A PWH=0.00 %  
Power: 12351.1 W P1=12351.2 W 12395.9 VA THC/Iref=2.79%  
Power factor: 0.996 C<sub>os</sub>Phi1: 0.999 PWHC/Iref=0.00%

Test conditons: EN 61000-3-12:2011, f=50 Hz, Phase=L2, Range=80.00 A  
Time window=10/12 (200ms), Grouping (>2nd harm.)=on, I<sub>eq</sub>=53.66 A, Rated R<sub>sce</sub>=33  
No Z<sub>test</sub> selected, Inserted reactor impedance: --  
harmonic currents < 1 % of I<sub>ref</sub> are disregard for calc. of THD, THC, POHC, PWH, PWHC

**HARMONIC ANALYSIS: Test PASS**

T<sub>obs</sub> = worst 2.5 min: tw 1..750; Avg: THC/Iref=2.7 % , PWHC/Iref=0.0 % (Limits: THC/Iref=13.0 % , PWHC/Iref=22.0 % ); I<sub>avg</sub>=53.660 Arms; I<sub>ref</sub> is setto I<sub>eq</sub>


Ha	Entire measurement (2.5 min = 750 time windows)						Worst 2.5 min		Worst 2.5 min avg		P A S S	F A I L
	Maximum	Window	EN61000-3-12 Balanced 3ph	Margin in MaxWin	100 to 150%	Ex- ceeded	100 to 150%	Ex- ceeded	Value	Ex- ceeded		
DC	3.5985 A	202	-----	-----	0	0	0	0	3.4671 A	0	--	
1	53.6543 A	115	-----	-----	0	0	0	0	53.5220 A	0	X	
2	1.2772 A	79	4.2928 A	-70.2 %	0	0	0	0	1.2094 A	0	X	
3	0.5986 A	655	-----	-----	0	0	0	0	0.5639 A	0	X	
4	0.6078 A	190	2.1464 A	-71.7 %	0	0	0	0	0.5174 A	0	X	
5	0.3000 A	641	5.7416 A	-94.8 %	0	0	0	0	0.2632 A	0	X	
6	0.6067 A	366	1.4309 A	-57.6 %	0	0	0	0	0.5673 A	0	X	
7	0.2590 A	535	3.8635 A	-93.3 %	0	0	0	0	0.2364 A	0	X	
8	0.0999 A	395	1.0732 A	-90.7 %	0	0	0	0	0.0692 A	0	X	
9	0.2054 A	70	-----	-----	0	0	0	0	0.1718 A	0	X	
10	0.2067 A	313	0.8586 A	-75.9 %	0	0	0	0	0.1677 A	0	X	
11	0.1688 A	434	1.6635 A	-89.9 %	0	0	0	0	0.1481 A	0	X	
12	0.1530 A	174	0.7155 A	-78.6 %	0	0	0	0	0.1037 A	0	X	
13	0.1122 A	340	1.0732 A	-89.5 %	0	0	0	0	0.0924 A	0	X	
14	0.1169 A	29	-----	-----	0	0	0	0	0.0670 A	0	X	
15	0.1101 A	186	-----	-----	0	0	0	0	0.0991 A	0	X	
16	0.0612 A	367	-----	-----	0	0	0	0	0.0324 A	0	X	
17	0.1354 A	238	-----	-----	0	0	0	0	0.1113 A	0	X	
18	0.0471 A	268	-----	-----	0	0	0	0	0.0341 A	0	X	
19	0.1397 A	727	-----	-----	0	0	0	0	0.1274 A	0	X	
20	0.0737 A	109	-----	-----	0	0	0	0	0.0466 A	0	X	
21	0.1607 A	115	-----	-----	0	0	0	0	0.1475 A	0	X	
22	0.0396 A	141	-----	-----	0	0	0	0	0.0255 A	0	X	
23	0.1638 A	562	-----	-----	0	0	0	0	0.1561 A	0	X	
24	0.0251 A	5	-----	-----	0	0	0	0	0.0172 A	0	X	
25	0.1525 A	85	-----	-----	0	0	0	0	0.1376 A	0	X	
26	0.0214 A	360	-----	-----	0	0	0	0	0.0165 A	0	X	
27	0.1217 A	81	-----	-----	0	0	0	0	0.1087 A	0	X	
28	0.0203 A	217	-----	-----	0	0	0	0	0.0160 A	0	X	
29	0.0996 A	297	-----	-----	0	0	0	0	0.0915 A	0	X	
30	0.0330 A	340	-----	-----	0	0	0	0	0.0242 A	0	X	
31	0.0850 A	66	-----	-----	0	0	0	0	0.0755 A	0	X	
32	0.0227 A	524	-----	-----	0	0	0	0	0.0123 A	0	X	
33	0.0775 A	1	-----	-----	0	0	0	0	0.0664 A	0	X	
34	0.0184 A	62	-----	-----	0	0	0	0	0.0136 A	0	X	
35	0.0588 A	156	-----	-----	0	0	0	0	0.0516 A	0	X	
36	0.0136 A	88	-----	-----	0	0	0	0	0.0097 A	0	X	
37	0.0544 A	478	-----	-----	0	0	0	0	0.0449 A	0	X	
38	0.0266 A	131	-----	-----	0	0	0	0	0.0222 A	0	X	
39	0.0553 A	6	-----	-----	0	0	0	0	0.0480 A	0	X	
40	0.0206 A	167	-----	-----	0	0	0	0	0.0161 A	0	X	

average value < 1.0 % of Iref

Tested with SPS EMC 44.3 / PAS1900 by Spitzenberger & Spies GmbH & Co. KG, Schmidstr. 32-34, 94234 Viechtach, Germany, 04.06.2021

HARMONIC CURRENT EMISSION V

Line - T



**HARMONIC CURRENT EMISSION VI**

Maximum RMS current and corresponding values in timewindow 2:

Voltage: 230.58 Vrms THD=0.02 % THV=0.047 V POHV=0.025 V PWH=0.06 %  
 Current: 53.614 Arms THD=1.53 % THC=0.820 A POHC=0.000 A PWH=0.00 %  
 Power: 12339.2 W P1=12339.3 W 12362.1 VA THC/Iref=1.53%  
 Power factor: 0.998 C<sub>os</sub>Phi1: 0.999 PWHC/Iref=0.00%

Test conditons: EN 61000-3-12:2011, f=50 Hz, Phase=L3, Range=80.00 A  
 Time window=10/12 (200ms), Grouping (>2nd harm.)=on, I<sub>eq</sub>=53.541 A, Rated R<sub>sc</sub>=33  
 No Ztest selected, Inserted reactor impedance: --  
 harmonic currents < 1 % of I<sub>ref</sub> are disregard for calc. of THD, THC, POHC, PWH, PWHC

**HARMONIC ANALYSIS: Test PASS**

Tobs = worst 2.5 min: tw 1..750; Avg: THC/Iref=1.4 % , PWHC/Iref=0.0 % (Limits: THC/Iref=13.0 % , PWHC/Iref=22.0 % ); I<sub>avg</sub>=53.541 Arms; I<sub>ref</sub> is setto I<sub>eq</sub>

Ha	Entire measurement (2.5 min = 750 time windows)						Worst 2.5 min		Worst 2.5 min avg		P A S S	F A I L
	Maximum	Window	EN61000-3-12 Balanced 3ph	Margin in MaxWin	100 to 150%	Ex- ceeded	100 to 150%	Ex- ceeded	Value	Ex- ceeded		
DC	1.9123 A	16	-----	-----	0	0	0	0	1.7886 A	0	--	
1	53.5662 A	2	-----	-----	0	0	0	0	53.4976 A	0	X	
2	0.5246 A	77	4.2833 A	-87.8 %	0	0	0	0	0.4808 A	0	X	
3	0.5706 A	225	-----	-----	0	0	0	0	0.5494 A	0	X	
4	0.4409 A	61	2.1416 A	-79.4 %	0	0	0	0	0.3764 A	0	X	
5	0.3361 A	673	5.7289 A	-94.1 %	0	0	0	0	0.3091 A	0	X	
6	0.6026 A	1	1.4278 A	-57.8 %	0	0	0	0	0.5420 A	0	X	
7	0.2656 A	120	3.8550 A	-93.1 %	0	0	0	0	0.2397 A	0	X	
8	0.1070 A	172	1.0708 A	-90.0 %	0	0	0	0	0.0785 A	0	X	
9	0.1918 A	4	-----	-----	0	0	0	0	0.1515 A	0	X	
10	0.3091 A	727	0.8567 A	-63.9 %	0	0	0	0	0.2929 A	0	X	
11	0.1418 A	279	1.6598 A	-91.5 %	0	0	0	0	0.1186 A	0	X	
12	0.1026 A	109	0.7139 A	-85.6 %	0	0	0	0	0.0843 A	0	X	
13	0.1154 A	526	1.0708 A	-89.2 %	0	0	0	0	0.1009 A	0	X	
14	0.1396 A	189	-----	-----	0	0	0	0	0.0986 A	0	X	
15	0.1056 A	477	-----	-----	0	0	0	0	0.0897 A	0	X	
16	0.0860 A	236	-----	-----	0	0	0	0	0.0648 A	0	X	
17	0.0865 A	60	-----	-----	0	0	0	0	0.0744 A	0	X	
18	0.0701 A	454	-----	-----	0	0	0	0	0.0531 A	0	X	
19	0.1523 A	133	-----	-----	0	0	0	0	0.1407 A	0	X	
20	0.0714 A	277	-----	-----	0	0	0	0	0.0600 A	0	X	
21	0.1613 A	413	-----	-----	0	0	0	0	0.1485 A	0	X	
22	0.0627 A	103	-----	-----	0	0	0	0	0.0489 A	0	X	
23	0.1410 A	336	-----	-----	0	0	0	0	0.1321 A	0	X	
24	0.0641 A	459	-----	-----	0	0	0	0	0.0520 A	0	X	
25	0.1473 A	192	-----	-----	0	0	0	0	0.1415 A	0	X	
26	0.0361 A	11	-----	-----	0	0	0	0	0.0224 A	0	X	
27	0.1280 A	741	-----	-----	0	0	0	0	0.1165 A	0	X	
28	0.0170 A	398	-----	-----	0	0	0	0	0.0118 A	0	X	
29	0.0891 A	243	-----	-----	0	0	0	0	0.0795 A	0	X	
30	0.0194 A	216	-----	-----	0	0	0	0	0.0139 A	0	X	
31	0.0850 A	247	-----	-----	0	0	0	0	0.0778 A	0	X	
32	0.0200 A	660	-----	-----	0	0	0	0	0.0131 A	0	X	
33	0.0707 A	235	-----	-----	0	0	0	0	0.0646 A	0	X	
34	0.0127 A	210	-----	-----	0	0	0	0	0.0094 A	0	X	
35	0.0627 A	164	-----	-----	0	0	0	0	0.0548 A	0	X	
36	0.0206 A	1	-----	-----	0	0	0	0	0.0160 A	0	X	
37	0.0547 A	705	-----	-----	0	0	0	0	0.0478 A	0	X	
38	0.0220 A	381	-----	-----	0	0	0	0	0.0171 A	0	X	
39	0.0570 A	182	-----	-----	0	0	0	0	0.0527 A	0	X	
40	0.0164 A	576	-----	-----	0	0	0	0	0.0125 A	0	X	

average value < 1.0 % of Iref

Tested with SPS EMC 44.3 / PAS1900 by Spitzenberger & Spjes GmbH & Co. KG, Schmidstr. 32-34, 94234 Viechtach, Germany, 04.06.2021

ELECTROSTATIC DISCHARGE IMMUNITY I							
<b>Technician:</b> Andreu Tey				<b>Test Area:</b> Ground plane			
<b>Test date:</b> 2021-06-16				<b>Criteria:</b> B			
<b>Resistance value:</b> 0.934MΩ							
<b>Basic standard:</b> IEC-61000-4-2:2008:2008							
<b>Temperature:</b>		23.0	°C				
<b>Humidity:</b>		59.6	%				
<b>Atm. Pressure:</b>		997.8	hPa				
<b>Result:</b> Pass							
<b>DC-</b> Direct Contact, sharp tip				<b>IH-</b> Horizontal coupling, Sharp tip.			
<b>AC-</b> Air Contact, round tip				<b>IV-</b> Vertical coupling, Sharp tip.			
Point	Level	Discharges		Pol +/-	Application point	Results	Comments
		Nº	Type				
1	4 kV	25	IV	+ -	0° Top	A	
2	4 kV	25	IV	+ -	0° Bottom	A	
3	4 kV	25	IV	+ -	90° Top	A	
4	4 kV	25	IV	+ -	90° Bottom	A	
5	4 kV	25	IH	+ -	180° Top	A	
6	4 kV	25	IH	+ -	180° Bottom	A	
7	4 kV	25	IH	+ -	270° Top	A	
8	4 kV	25	IH	+ -	270° Bottom	A	
9	4 kV	25	DC	+ -	Front	A	
10	4 kV	25	DC	+ -	Right side	A	
11	4 kV	25	DC	+ -	Left side	A	
12	4 kV	25	DC	+ -	Rear	A	
13	4 kV	25	DC	+ -	Top	A	
14	4 kV	25	DC	+ -	Metallic support	A	
15	4 kV	25	DC	+ -	Screws	A	
16	4 kV	25	DC	+ -	RS-232 HOUSING	A	
14	4 kV	25	DC	+ -	USB HOUSING	A	
15	4 kV	25	DC	+ -	LAN HOUSING	A	
<b>Comments:</b>							
ND: Not discharges.							
No evidence of malfunctioning was detected in the EUT during the test.							

**The tests / inspections marked with \* are not covered by the accreditation of ENAC**

ELECTROSTATIC DISCHARGE IMMUNITY II							
<b>Technician:</b> Andreu Tey				<b>Test Area:</b> Ground plane			
<b>Test date:</b> 2021-06-16				<b>Criteria:</b> B			
<b>Resistance value:</b> 0.934MΩ							
<b>Basic standard:</b> IEC-61000-4-2:2008:2008							
<b>Temperature:</b>		23.0	°C				
<b>Humidity:</b>		59.6	%				
<b>Atm. Pressure:</b>		997.8	hPa				
<b>Result:</b> Pass							
<b>DC-</b> Direct Contact, sharp tip				<b>IH-</b> Horizontal coupling, Sharp tip.			
<b>AC-</b> Air Contact, round tip				<b>IV-</b> Vertical coupling, Sharp tip.			
Point	Level	Discharges		Pol +/-	Application point	Results	Comments
		Nº	Type				
16	8 kV	25	AC	+	PLASTIC DOOR LOCKS	A	ND
				-			
14	8 kV	25	AC	+	DISPLAY CHASSIS	A	
				-			
15	8 kV	25	AC	+	DISPLAY	A	
				-			
<b>Comments:</b>							
ND: Not discharges.							
No evidence of malfunctioning was detected in the EUT during the test.							

ELECTROMAGNETIC FIELD IMMUNITY				
<b>Technician:</b> J.J.Permos; A. Plans		<b>Test Area:</b> Semi-Anechoic chamber, SAC-0		
<b>Test date:</b> 2021-05-10		<b>Criteria:</b> A		
<b>Basic standard:</b> IEC 61000-4-3:2006/ISH1:2008				
<b>Temperature:</b> 22.5 °C				
<b>Humidity:</b> 60.1 %				
<b>Atm. Pressure:</b> 1007.3 hPa				
Frequency range	80 MHz – 1000 MHz		1000 MHz- 6000 MHz	
Severity	10 V/m		10 V/m	
Antenna type	Log Periodic		Log Periodic	
Frequency step	1%		1%	
Dwell time	3 s		3 s	
Modulation	80% AM 1 kHz		PM 200Hz	
Dist. DUT/antenna	3 m	3 m	3 m	3 m
Polarization	H	V	H	V
FACE	FRONTAL 0°	A	A	NA
	LEFT 90°	A	A	NA
	REAR180°	A	A	NA
	RIGHT 270°	A	A	NA
<b>RESULTS:</b> Pass				
<b>Comments:</b>				
No evidence of malfunctioning was detected in the EUT during the test.				

FAST TRANSIENTS IN BURST IMMUNITY														
<b>Technician:</b> Antonio Mayayo			<b>Test Area:</b> Ground plane											
<b>Test date:</b> 2021-05-11			<b>Criteria:</b> B											
<b>Basic standard:</b> IEC 61000-4-4:2012														
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>22.3</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>55.1</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1007.2</td> <td>hPa</td> </tr> </table>						<b>Temperature:</b>	22.3	°C	<b>Humidity:</b>	55.1	%	<b>Atm. Pressure:</b>	1007.2	hPa
<b>Temperature:</b>	22.3	°C												
<b>Humidity:</b>	55.1	%												
<b>Atm. Pressure:</b>	1007.2	hPa												
<b>Result:</b> Pass														
Test ports	Application	Severity (kV)	Duration	Results	Comments									
<b>AC supply</b>	L1+L2+L3+GND	+2	2 min	A	5 kHz									
		-2	2 min	A										
<b>LOADS</b>	Clamp	+2	2 min	A	5 kHz									
		-2	2 min	A										
<b>Comments:</b>														
No evidence of malfunctioning was detected in the EUT during the test.														

SURGE TRANSIENTS IMMUNITY (1,2/50) I																		
<b>Technician:</b> Andreu Tey, Adrián Pérez					<b>Test Area:</b> Ground plane													
<b>Test date:</b> 2021-06-08					<b>Criteria:</b> B													
<b>Basic standard:</b> IEC 61000-4-5:2014/Amd1:2017																		
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>24.3</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>50.9</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1002.9</td> <td>hPa</td> </tr> </table>										<b>Temperature:</b>	24.3	°C	<b>Humidity:</b>	50.9	%	<b>Atm. Pressure:</b>	1002.9	hPa
<b>Temperature:</b>	24.3	°C																
<b>Humidity:</b>	50.9	%																
<b>Atm. Pressure:</b>	1002.9	hPa																
<b>Result:</b> Pass																		
Application	Zo	Line	Phase	Severity (kV)	Nº Pulses		Results		Comments									
					+	-	Polarity +	Polarity -										
<b>AC INPUT POWER SUPPLY</b>																		
Line to line	2	L1 / L2	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L2 / L3	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L1 / L3	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L1 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L2 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L3 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
<b>Comments:</b>																		
No evidence of malfunctioning was detected in the EUT during the test.																		

SURGE TRANSIENTS IMMUNITY (1,2/50) II																		
<b>Technician:</b> Adrián Pérez					<b>Test Area:</b> Ground plane													
<b>Test date:</b> 20210-06-18 / 2021-07-17					<b>Criteria:</b> B													
<b>Basic standard:</b> IEC 61000-4-5:2014/Amd1:2017																		
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>25.4</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>43.7</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1000.4</td> <td>hPa</td> </tr> </table>										<b>Temperature:</b>	25.4	°C	<b>Humidity:</b>	43.7	%	<b>Atm. Pressure:</b>	1000.4	hPa
<b>Temperature:</b>	25.4	°C																
<b>Humidity:</b>	43.7	%																
<b>Atm. Pressure:</b>	1000.4	hPa																
<b>Result:</b> Pass																		
Application	Zo	Line	Phase	Severity (kV)	N° Pulses		Results		Comments									
					+	-	Polarity +	Polarity -										
<b>AC INPUT POWER SUPPLY</b>																		
Line to ground	12	L1 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	L2 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	L3 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	N / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
<b>Comments:</b>																		
No evidence of malfunctioning was detected in the EUT during the test.																		

SURGE TRANSIENTS IMMUNITY (1,2/50) III																		
<b>Technician:</b> Andreu Tey, Adrián Pérez					<b>Test Area:</b> Ground plane													
<b>Test date:</b> 2021-06-08					<b>Criteria:</b> B													
<b>Basic standard:</b> IEC 61000-4-5:2014/Amd1:2017																		
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>23.7</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>51.6</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1003.2</td> <td>hPa</td> </tr> </table>										<b>Temperature:</b>	23.7	°C	<b>Humidity:</b>	51.6	%	<b>Atm. Pressure:</b>	1003.2	hPa
<b>Temperature:</b>	23.7	°C																
<b>Humidity:</b>	51.6	%																
<b>Atm. Pressure:</b>	1003.2	hPa																
<b>Result:</b> Pass																		
Application	Zo	Line	Phase	Severity (kV)	Nº Pulses		Results		Comments									
					+	-	Polarity +	Polarity -										
<b>AC OUTPUT POWER SUPPLY</b>																		
Line to line	2	L1 / L2	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L2 / L3	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L1 / L3	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L1 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L2 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L3 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
<b>Comments:</b>																		
No evidence of malfunctioning was detected in the EUT during the test.																		

SURGE TRANSIENTS IMMUNITY (1,2/50) IV																		
<b>Technician:</b> Adrián Pérez					<b>Test Area:</b> Ground plane													
<b>Test date:</b> 2021-06-18 / 2021-06-17					<b>Criteria:</b> B													
<b>Basic standard:</b> IEC 61000-4-5:2014/Amd1:2017																		
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>25.4</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>43.7</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1000.4</td> <td>hPa</td> </tr> </table>										<b>Temperature:</b>	25.4	°C	<b>Humidity:</b>	43.7	%	<b>Atm. Pressure:</b>	1000.4	hPa
<b>Temperature:</b>	25.4	°C																
<b>Humidity:</b>	43.7	%																
<b>Atm. Pressure:</b>	1000.4	hPa																
<b>Result:</b> Pass																		
Application	Zo	Line	Phase	Severity (kV)	N° Pulses		Results		Comments									
					+	-	Polarity +	Polarity -										
<b>AC OUTPUT POWER SUPPLY</b>																		
Line to ground	12	L1 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	L2 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	L3 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	N / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
<b>Comments:</b>																		
No evidence of malfunctioning was detected in the EUT during the test.																		

SURGE TRANSIENTS IMMUNITY (1,2/50) III																		
<b>Technician:</b> Adrián Pérez					<b>Test Area:</b> Ground plane													
<b>Test date:</b> 2021-06-08					<b>Criteria:</b> B													
<b>Basic standard:</b> IEC 61000-4-5:2014/Amd1:2017																		
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>24.3</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>50.9</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1002.9</td> <td>hPa</td> </tr> </table>										<b>Temperature:</b>	24.3	°C	<b>Humidity:</b>	50.9	%	<b>Atm. Pressure:</b>	1002.9	hPa
<b>Temperature:</b>	24.3	°C																
<b>Humidity:</b>	50.9	%																
<b>Atm. Pressure:</b>	1002.9	hPa																
<b>Result:</b> Pass																		
Application	Zo	Line	Phase	Severity (kV)	Nº Pulses		Results		Comments									
					+	-	Polarity +	Polarity -										
<b>AC OUTPUT POWER SUPPLY</b>																		
Line to line	2	L1 / L2	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L2 / L3	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L1 / L3	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L1 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L2 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
Line to line	2	L3 / N	0°	1	5	5	A	A										
			90°	1	5	5	A	A										
			180°	1	5	5	A	A										
			270°	1	5	5	A	A										
<b>Comments:</b>																		
No evidence of malfunctioning was detected in the EUT during the test.																		

SURGE TRANSIENTS IMMUNITY (1,2/50) IV																		
<b>Technician:</b> Adrián Pérez					<b>Test Area:</b> Ground plane													
<b>Test date:</b> 2021-06-18 / 2021-07-17					<b>Criteria:</b> B													
<b>Basic standard:</b> IEC 61000-4-5:2014/Amd1:2017																		
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>25.4</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>43.7</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1000.4</td> <td>hPa</td> </tr> </table>										<b>Temperature:</b>	25.4	°C	<b>Humidity:</b>	43.7	%	<b>Atm. Pressure:</b>	1000.4	hPa
<b>Temperature:</b>	25.4	°C																
<b>Humidity:</b>	43.7	%																
<b>Atm. Pressure:</b>	1000.4	hPa																
<b>Result:</b> Pass																		
Application	Zo	Line	Phase	Severity (kV)	Nº Pulses		Results		Comments									
					+	-	Polarity +	Polarity -										
<b>AC OUTPUT POWER SUPPLY</b>																		
Line to ground	12	L1 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	L2 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	L3 / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
Line to ground	12	N / E	0°	2	5	5	A	A										
			90°	2	5	5	A	A										
			180°	2	5	5	A	A										
			270°	2	5	5	A	A										
<b>Comments:</b>																		
No evidence of malfunctioning was detected in the EUT during the test.																		

CURRENT INJECTIONS IMMUNITY													
<b>Technician:</b> Antonio Mayayo		<b>Test Area:</b> Ground plane											
<b>Test date:</b> 2021-05-11		<b>Criteria:</b> A											
<b>Level of Severity:</b> 10 V RMS		<b>Part of a system?:</b> No											
<b>Frequency range:</b> 150 kHz - 80 MHz		<b>Dwell time:</b> 3s											
<b>Modulation:</b> 80% AM 1 kHz		<b>Increase:</b> 1%											
<b>Basic standard:</b> IEC 61000-4-6:2013/Corr1:2015													
<table border="1" style="width: 100%;"> <tr> <td><b>Temperature:</b></td> <td>21.9</td> <td>°C</td> </tr> <tr> <td><b>Humidity:</b></td> <td>56.0</td> <td>%</td> </tr> <tr> <td><b>Atm. Pressure:</b></td> <td>1007.4</td> <td>hPa</td> </tr> </table>					<b>Temperature:</b>	21.9	°C	<b>Humidity:</b>	56.0	%	<b>Atm. Pressure:</b>	1007.4	hPa
<b>Temperature:</b>	21.9	°C											
<b>Humidity:</b>	56.0	%											
<b>Atm. Pressure:</b>	1007.4	hPa											
<b>Result:</b> Pass													
CDN	Severity (V)	Application point	Results	Comments									
CLAMP	10V	AC supply	A										
CLAMP	10V	LOADS	A										
<b>Comments:</b>													
No evidence of malfunctioning was detected in the EUT during the test.													

LOW FREQUENCY MAGNETIC FIELDS IMMUNITY																			
<b>Technician:</b> Andreu Tey		<b>Test Area:</b> Ground plane																	
<b>Test date:</b> 2021-06-16																			
<b>Applied voltage to coil (Vrms):</b> 27.3 V		<b>Stabilizing EUT time:</b> 15 minutes																	
<b>Ambient measure (A/m):</b> 0.209 A/m																			
<b>Basic standard:</b> IEC 61000-4-8:2009																			
<table border="1"><tr><td><b>Temperature:</b></td><td>22.3</td><td>°C</td><td colspan="2"></td></tr><tr><td><b>Humidity:</b></td><td>64.3</td><td>%</td><td colspan="2"></td></tr><tr><td><b>Atm. Pressure:</b></td><td>1014.5</td><td>hPa</td><td colspan="2"></td></tr></table>					<b>Temperature:</b>	22.3	°C			<b>Humidity:</b>	64.3	%			<b>Atm. Pressure:</b>	1014.5	hPa		
<b>Temperature:</b>	22.3	°C																	
<b>Humidity:</b>	64.3	%																	
<b>Atm. Pressure:</b>	1014.5	hPa																	
<b>Result:</b> Pass																			
<b>50Hz</b>																			
Axe	Intensity (A/m)	Field type	Results	Comments:															
X	30	Continuous field (5min)	A																
Y	30	Continuous field (5min)	A																
Z	30	Continuous field (5min)	A																
<b>Comments:</b>																			
No evidence of problem was detected in the EUT during or after the test.																			

<b>HARMONIC AND INTERHARMONIC IMMUNITY</b>					
<b>Technician:</b> Andreu Tey		<b>Test Area:</b> Ground plane			
<b>Test date:</b> 04/06/2021					
<b>Basic standard:</b> *IEC 61000-4-13:2002/AMD:2015, *IEC 61000-2-2:2002					
<b>RESULTS:</b> Pass					
Test conditions:	EN 61000-4-13 Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests  230.0 Vrms / 50.0 Hz EN 61000-4-13:2002 + A1:2009 + A2:2016 class X(course 3)				
Flat curve:	Cut off level:	0.90	Voltage ratio Ky:	1.0379	120.0 sec
	Test time:	120.0 sec			
Over swing:	Level 3rd harmonic:	6.0 %	Level 5th harmonic:	4.0 %	120.0 sec
	Test time:	120.0 sec			
	Any functional anomalies (decision by tester):				NO
Sweep in frequencies:	Level 0.33*f to 2*f:	3.0 %	Level 2*f to 10*f:	9.0 %	5.0 min per decade
	Level 10*f to 20*f:	4.5 %	Level 20*f to 30*f:	2.0 %	
	Level 30*f to 40*f:	2.0 %	Time per decade:	5.0 min	
	Any functional anomalies (decision by tester):				YES
Individual harmonics:	Lv. 02: 03.0 %	Lv. 03: 08.0 %	Lv. 04: 01.5 %	Lv. 05: 09.0 %	5 sec per harm.
	Lv. 06: 00.0 %	Lv. 07: 07.5 %	Lv. 08: 00.0 %	Lv. 09: 02.5 %	
	Lv. 10: 00.0 %	Lv. 11: 05.0 %	Lv. 12: 00.0 %	Lv. 13: 04.5 %	
	Lv. 14: 00.0 %	Lv. 15: 00.0 %	Lv. 16: 00.0 %	Lv. 17: 03.0 %	
	Lv. 18: 00.0 %	Lv. 19: 02.0 %	Lv. 20: 00.0 %	Lv. 21: 00.0 %	
	Lv. 22: 00.0 %	Lv. 23: 02.0 %	Lv. 24: 00.0 %	Lv. 25: 02.0 %	
	Lv. 26: 00.0 %	Lv. 27: 00.0 %	Lv. 28: 00.0 %	Lv. 29: 01.5 %	
	Lv. 30: 00.0 %	Lv. 31: 01.5 %	Lv. 32: 00.0 %	Lv. 33: 00.0 %	
	Lv. 34: 00.0 %	Lv. 35: 01.5 %	Lv. 36: 00.0 %	Lv. 37: 01.5 %	
	Lv. 38: 00.0 %	Lv. 39: 00.0 %	Lv. 40: 00.0 %		
Indiv. interharmonics:	Level 16.5 to 100 Hz:	2.5 %	Level 100 to 500 Hz:	5.0 %	5 sec per interharr
	Level 500 to 750 Hz:	3.5 %	Level 750 to 1000 Hz:	2.0 %	
	Level 1000 to 2000 Hz:	1.5 %			
	Any functional anomalies (decision by tester):				NO
Resonance points:	--				
<b>Comments:</b>					
No evidence of problem was detected in the EUT during or after the test.					