

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible Power System (UPS)

Name and address of the applicant

Salicru S.A.
Avda. de la Serra, 100,
08460 Sta. Ma de Palautordera, BARCELONA, Spain

Name and address of the manufacturer

same as applicant

Name and address of the factory

same as applicant

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

INPUT : 3x380 / 3x400 / 3x415 V (3P+N), 50/60 Hz,
OUTPUT : 3x380 / 3x400 / 3x415 V (3P+N), 50/60 Hz,
Class I, IP20
SLC-30-CUBE4: 30000 W
SLC-40-CUBE4: 40000 W
SLC-50-CUBE4: 50000 W
SLC-60-CUBE4: 60000 W
SLC-80-CUBE4: 80000 W

Trademark (if any)

SALICRU

Customer's Testing Facility (CTF) Stage used

CTF – Stage 1

Model / Type Ref.

**SLC-30-CUBE4, SLC-40-CUBE4, SLC-50-CUBE4,
SLC-60-CUBE4, SLC-80-CUBE4**

Additional information (if necessary may also be reported on page 2)

-
 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017(ed. 2.0)

National Differences:

EU Group Differences (No specific countries addressed).

As shown in the Test Report Ref. No. which forms part of this Certificate

2221/0040

This CB Test Certificate is issued by the National Certification Body

SGS Belgium NV - Division SGS CEBEC
Riverside Business Park
Avenue Internationalelaan 55, Building K
B-1070 Brussels, Belgium

Date: 10/05/2022

Signature: Daniel Arranz