



# EVPU<sup>®</sup>

NOTIFIED BODY No. 1293

## EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0351

of September 12, 2012

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### Interface module for conventional detectors MC500

based on a microcontroller and equipped with a short circuit isolator, the interface module MC500 is used to connect conventional detectors to the Elkron FAP addressed fire detection system series

placed on the market by

**URMET S.p.A.**

**Via Bologna 188/C, 10154 Torino, Italy**

and produced in the factory

**VAT No. IT05288880965**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPU a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

**EN 54-17: 2005/AC: 2007, EN 54-18: 2005/AC: 2007**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on September 12, 2012 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Marek H u d á k

The   
**1293**

045556

Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.