



| | | | |
|---------------|-------------|-----------------|------------------------------|
| Number | 19GR0341/02 | Replaces | 19GR0341/01 |
| Issue date | 18-10-2021 | Contract number | E9010 |
| Due date | 18-10-2031 | Module | B (Type testing) |
| Report number | 178257 | Scope | (EU) 2016/426 (9 March 2016) |
| PIN | 0063CP3257 | Page | 1 of 1 |

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer: Zehnder Group Zwolle BV

Type: CombiFlow

Appliance types: (N.A.)

Appliance categories: (N.A.)

Gas groups and supply pressures: (N.A.)

Country of destination:

the Netherlands

Remarks:

With the CombiFlow flue gas adapter, the Zehnder WHR 930 and Zehnder ComfoAir Standard 300 heat recuperation units can be combined with the following boiler models:

Nefit ProLine NxT HRC 24 CW3,

Nefit ProLine NxT HRC 24 CW4,

Nefit ProLine NxT HRC 30 CW5,

Intergas Kombi Kompakt HRE 24/18

Intergas Kombi Kompakt HRE 28/24,

Intergas Kombi Kompakt HRE 36/30,

Remeha Tzerra Ace 24c

Remeha Tzerra Ace 28c

Remeha Tzerra Ace 39c

Intergas Kombi Kompakt HReco 24

Intergas Kombi Kompakt HReco 30

Intergas Kombi Kompakt HReco 36

Remeha Avanta Ace 24c (CCS)

Remeha Avanta Ace 28c (CCS)

Remeha Avanta Ace 35c (CCS)